

MEPNN Supplier Scouting Opportunity Synopsis

Section 1: General Information

| | |
|--------------------|---|
| Scouting Number | 2025-311 |
| Item to be Scouted | BABA Compliant Termination Bar |
| Days to be scouted | 26 |
| Response Due By | 09/29/2025 |
| Description | BABA Compliant: Termination bars, seaming tapes, and similar components. 2. Acceptable Manufacturers: |

Section 2: Technical Information

| | |
|---|---|
| Type of supplier being sought | Other |
| Details | Colorado BABAA-compliant self-certified manufacturers |
| Reason | BABA |
| Describe the manufacturing processes (elaborate to provide as much detail as possible) | Domestic components in each of the BABAA compliant manufactured products must exceed 55% of the total component cost and be assembled in the United States. |
| Provide dimensions / size / tolerances / performance specifications for the item | See attached specs and mechanical schedule for more information. |
| List required materials needed to make the product, including materials of product components | See attached specs and mechanical schedule for more information. |
| Are there applicable certification requirements? | Yes |
| Details | Build America, Buy America Act (BABAA) compliant |
| Are there applicable regulations? | Yes |
| Details | Must be able to submit BABAA manufactured product self-certification manufactured product letter that details a compliant product. |
| Are there any other standards, requirements, etc.? | No |
| Additional Technical Comments | See attached specs and mechanical schedule for more information. |

Section 4: Business Information

| | |
|---|---|
| Estimated potential business volume | TBD post selection. Cost should be the best available, and cannot increase the project cost by 25%. |
| Estimated target price / unit cost information (if unavailable explain) | TBD post selection. Cost should be the best available, and cannot increase the project cost by 25%. |
| When is it needed by? | Q1 2026 |
| Describe packaging requirements | Must arrive undamaged |
| Where will this item be shipped? | Colorado |

Additional Comments

| | |
|---|---|
| Is there other information you would like to include? | <p>Nationwide Search</p> <p>Provide written documentation in response to the Supplier Scouting request of being a current Build America Buy America Act Termination Bars distributor with experience in manufacturing the system components, meeting the product performance requirements.</p> <p>Information on BABAA compliance requirements can be found at the Made in America Office link https://www.madeinamerica.gov/.</p> |
|---|---|

- C. Admixtures: Not permitted unless specified, or requested by Contractor in writing and approved in writing by Architect.

2.03 REINFORCEMENT AND ANCHORAGE

- A. **Single Wythe Joint Reinforcement: ASTM A951/A951M.**
 - 1. **Type: Truss.**
 - 2. Material: ASTM A1064/A1064M steel wire, mill galvanized to ASTM A641/A641M Class 3.
 - 3. Size: 0.1483 inch side rods with 0.1483 inch cross rods; width as required to provide not less than 5/8 inch of mortar coverage on each exposure.
- B. **Two-Piece Wall Ties:** Formed steel wire, 0.1875 inch thick, adjustable, eye and pintle type, hot dip galvanized to ASTM A 153/A 153M, Class B, sized to provide not less than 5/8 inch of mortar coverage from masonry face and to allow vertical adjustment of up to 1-1/4 inch; self-sealing head flange.
 - 1. Acceptable Product:
 - a. Wire-Bond; Sure-Tie or Tapcon Sure-Tie: www.wirebond.com.
 - b. Substitutions: See Section 01 6000 - Product Requirements.

2.04 FLASHINGS

- A. **Stainless Steel/Polymer Fabric Drainage Plane Flashing: ASTM A240/A240M; 2 mil type 304 stainless steel sheet bonded between one sheet of polymer fabric and one sheet of non-woven drainage material.**
 - 1. Accessories: Provide all accessory components required by manufacturer for complete system, including termination bars, seaming tapes, and similar components.
 - 2. Acceptable Manufacturer:
 - a. York Manufacturing, Inc.; Flash-Vent SS: www.yorkmfg.com.
 - b. Substitutions: See Section 01 6000 - Product Requirements.
- B. Lap Sealants and Tapes: As recommended by flashing manufacturer; compatible with membrane and adhesives.

2.05 ACCESSORIES

- A. Weeps and Cavity Vents: Molded PVC grilles, insect resistant.
 - 1. Width: Match specified mortar joint thickness; 3/8 inch, unless otherwise indicated.
 - 2. Height: Match height of applicable masonry unit, plus 3/8 inch.
 - 3. Depth: Match depth of applicable masonry unit, plus 1/4 inch.
 - 4. Color(s): As selected by Architect from manufacturer's full range.
- B. Cleaning Solution: Non-acidic, not harmful to masonry work or adjacent materials.
 - 1. Acceptable Product:
 - a. ProSoCo, Inc.; Safety Clean: www.prosoco.com.
 - b. Substitutions: See Section 01 6000 - Product Requirements.

2.06 **LINTELS** **Installation only**

- A. Steel Lintels: Specified in Section 05 5000.

2.07 MORTAR MIXES

- A. Mortar for Unit Masonry: ASTM C270, using the Property Specification.
 - 1. Masonry Below Grade in Contact With Earth: Type S.
 - 2. Exterior Non-loadbearing Masonry: Type N.